



INPUT TERMINALS 3 & 4 CAN BE POWERED USING THE GENERATOR ITSELF, AN AUXILIARY WINDING OR A PMG.

THE INPUT OF 3 & 4 MUST BE FROM 60 TO 277 Vac and from 60 to 400 HERTZ

See Regulator instructions for more information

